

FUGRO TECHNICAL SERVICES LIMITED

MaterialLab Division,
 Fugro Development Centre,
 5 Lok Yi Street, 17 M.S. Castle Peak Road,
 Tai Lam, Tuen Mun, N.T., Hong Kong.

Tel : +852-2450 8233
 Fax : +852-2450 6138
 E-mail : matlab@fugro.com.hk
 Website : www.fugro.com

MaterialLab

Client Ref. : --
 Report No. : 031943ST41538(1)

Page 1 of 3

REPORT ON COLOUR RENTENTION TEST OF VITREOUS ENAMEL PANEL**Information Supplied by Client**

Client : Pantech (Metal Panel) Technologies Limited
 Project : Testing for Vitreous Enamel Panel
 Sample Description : Pantech Vitreous Enamel Panel
 Colour : RAL 6005-Green


Laboratory Information

Lab. Sample I.D. : ST41538/4
 Date Received : 03 August 2004
 Date Test Started : 03 August 2004
 Date Test Completed : 04 August 2004
 Test Method : ASTM C538-83 (re-approved 1998)

Test Results

| Lab. Sample I.D. | Reading of Gloss Meter | | Observation | ASTM Requirement |
|------------------|------------------------|------------|----------------------|----------------------|
| | Before Test | After Test | | |
| ST41538/4 | 95 | 83 | No visible darkening | No visible darkening |

Remarks : (1.) The test results relate only to the sample tested.
 (2.) The test in progress, sample before and after test are shown in the photographs on pages 2 and 3 of this report.

Checked By : Stewart Uken Date : 11/08/2004 Certified By :  Date : 12/8/04
 Gary Winstanley

The copyright of this document is owned by Fugro Technical Services Limited. It may not be reproduced except with prior written approval from the Company.

FUGRO TECHNICAL SERVICES LIMITED


MateriaLab Division,
Fugro Development Centre,
5 Lok Yi Street, 17 M.S. Castle Peak Road,
Tai Lam, Tuen Mun, N.T., Hong Kong.

Tel : +852-2450 8233
Fax : +852-2450 6138
E-mail : matlab@fugro.com.hk
Website : www.fugro.com


MateriaLab

Client Ref. : --
Report No. : 031943ST41538(1)

Page 2 of 3



Before Test
Sample I.D. : ST41538/4



Test in Progress
Sample I.D. : ST41538/4

FUGRO TECHNICAL SERVICES LIMITED

MaterialLab Division,
Fugro Development Centre,
5 Lok Yi Street, 17 M.S. Castle Peak Road,
Tai Lam, Tuen Mun, N.T., Hong Kong.

Tel : +852-2450 8233
Fax : +852-2450 6138
E-mail : matlab@fugro.com.hk
Website : www.fugro.com

MaterialLab

Client Ref. : —
Report No. : 031943ST41538(1)

Page 3 of 3



After Test
Sample I.D. : ST41538/4